



MUNICIPAL CORPORATION CHANDIGARH

Public Health Laboratory at Water Works Sector - 39

TEST - REPORT

Not for legal use

Ref. No. & Date :- No. GMSSS/MHC/MM/2024/408 dated 18.04.2024
Issued to :- The Principal,
:- Govt. Model Sr. Sec. School
:- Modern Housing Complex, Manimajra, U.T. Chd
Quantity of sample :- Approximate 1200 ml .
Date of Collection :- 19-04-2024
Client reference :- Sample Collected by Laboratory Staff
Packing of sample :- Sample Filled in P.P. and Glass Bottle
Source of sample :- from School tap of Govt. Model Sr. Sec. School
MHC, Manimajra, U.T. Chandigarh.


S.No.	Examination	Quality Standard	Unit	Result
1	pH	6.5 - 8.5	----	7.38
2	Odour	Agreeable	----	Agreeable
3	Taste	Agreeable	----	Agreeable
4	Turbidity	< 1.0	mg/l	0.7
5	Residual Chlorine	0.2 - 0.4	mg/l	0.2
6	Total Alkalinity (as CaCO ₃)	< 200	mg/l	292
7	Total Hardness (as CaCO ₃)	< 200	mg/l	126
8	Chloride (as Cl)	< 250	mg/l	09
9	Free & Saline Ammonia	Nil	mg/l	NIL
10	Total Dissolved Solids	< 500	mg/l	318
11	M.P.N. of Coliform Bacilli Per 100ml of water	Zero	M.P.N.	0 (Excellent)


Payment received vide receipt No.04/2024-25/188299, dated 18.04.2024, Amount Rs.3300/-

Note:- Water is fit for drinking

Lab No.- MCPHL/24/1506.....

Dated:- 22.04.2024



Chemist
M.C.P.H. Laboratory
Chandigarh



Sub Divisional Engineer,
M.C.P.H. Sub Division No.1
Chandigarh

Dated :-22.04.2024

Endst No. MCPH/24/.....

Copy forwarded to the Medical Officer of Health Municipal Corporation, Sector-17, Chandigarh
For Information Please.


Chemist
M.C.P.H. Laboratory
Chandigarh


Sub Divisional Engineer,
M.C.P.H. Sub Division No.1
Chandigarh